

# SKG-IKOB PRODUCTCERTIFICATE

## 404.212.09

Date of issue: 20-06-2022



### Certificate holder

Fuhr GmbH & Co KG  
Carl Fuhr Straße 12  
D-42579 Heiligenhaus  
T: +49 (0) 2056 5920  
E: info@fuhr.de  
I: www.fuhr.de



### Declaration of SKG-IKOB

This certificate has been issued on the basis of BRL 3104 in accordance with the SKG-IKOB Regulations for Attestation, Certification and Inspection.

SKG-IKOB declares that the by or on behalf of the certificate owner produced building hardware product:

**cylinder mortice multipointlock wo electromechanical**

delivered under logo / brand:

**FUHR**

delivered under type- and / or article number:

**835/3 , 836/3 - type 10 SKG2**

meets class 2 STER according BRL 3104 and NEN 5089: 2009 if the product is indelibly marked with the SKG mark, as shown above.

For SKG-IKOB

A blue ink handwritten signature, appearing to be "H.A.J. van Dartel", written over a horizontal line.

ir. H.A.J. van Dartel  
Certification manager

Verify at [www.sterrenwijzer.nl](http://www.sterrenwijzer.nl) if this certificate is still valid and actual.  
This certificate contains 2 pages.

CERTIFICATE

SKG-IKOB Certificatie  
Poppenbouwing 56  
4191 NZ Geldermalsen

Postbus 202  
4190 CE Geldermalsen

T 088-2440100  
info@skgikob.nl  
www.skgikob.nl

# SKG-IKOB PRODUCTCERTIFICATE

Fuhr GmbH & Co KG  
Number: 404.212.09

page 2 of 2

## 1. PRODUCT

cylinder mortice multipointlock wo electromechanical

## PRODUCT TYPE

multipoint lock

---

## 2. TECHNICAL SPECIFICATION

Operating:	Mechanical and electrical operation
Construction:	1 forend with main lock with square bolt and var. type latches + 2 additional hook-pin bolts
System:	self-locking, key or electronic operated lockable by 17 mm profile cylinder or electronic PZ: 92 mm , BS: 35~80 mm
Material:	forend and lock cases: steel zinc coated
Dimension:	forend: 1800/2405 mm x (U)16~30x3 mm lock cases: 200xBS+18x15 mm / 135x40x15 mm
Fixing:	Ø 4 mm in steel reinforcement min. 1,5 mm
Intended use:	PVC, door-inward-opening, door-outward-opening in combination with FUHR box keepers or keeperstrip: 404.611.01

---

## 3. DELIVERY

The delivery includes an installation instruction:  
1-0800-008 OR 1-0800-025

---

## 4. PERFORMANCES

A cylinder mortice multipointlock wo electromechanical according this certificate fulfils the relevant requirements of BRL 3104.

A window- or door set, in which this cylinder mortice multipointlock wo electromechanical is installed according the installation instructions of the certificate holder meets at least burglar resistance class (RC) 2 of NEN 5096 and EN 1627, if:

the façade element or the (profile-)system from which the element is manufactured is delivered under a (KOMO-)quality approval with respect to the aspect burglar resistance, in which the actual window or door type is admitted and the herein mentioned conditions are fulfilled.

A window or door, in existing buildings, in which this cylinder mortice multipointlock wo electromechanical is installed according the installation instructions of the certificate holder, meets the requirements of the Police Mark Save Housing (PKVW) - Existing Building, if:

the other aspects of the façade element also comply with the applicable PKVW Protection directive (publication CCV).

---